



NOTES:

1. COMPACTION REQUIREMENTS AS PER DETAILS SPECIFICATIONS.
2. ALL DIMENSIONS GIVEN IN MILLIMETRES.
3. DEPTH OF COVER TO BE CONFIRMED BY THERMAL ANALYSIS.
4. RISER REQUIRED WHERE MAIN IS IN EXCESS OF 4.5m DEEP. RISERS SHALL BE INSTALLED TO WITHIN 3.6m OF FINISHED GRADE.
5. 50x100 MARKER TO EXTEND TO INVERT OF SERVICE (PAINTED).



SANITARY SEWER
SERVICE CONNECTION RISER

DATE: JANUARY 2007

STD DWG

A6.2