



NOTES:

- 1) ALL FITTINGS ARE TO BE BRASS.
- 2) IRRIGATION TYPE WATER SERVICE SHALL BE USED WITH BLEEDER INSTALLATION
- 3) ALL TEST COCKS SHALL BE CAPPED.
- 4) BLEEDER PIPE TO BE STUBBED A MINIMUM OF 300mm INSIDE MANHOLE FOR FUTURE CONNECTION
- 5) 600mm LENGTH OF WATER HEAT TRACE WIRE SHALL BE TERMINATED IN CHAMBER FOR FUTURE USE
- 6) MANHOLE SHALL HAVE FROST COVER AS PER STANDARD DETAIL
- 7) BLEEDER ASSEMBLY TO BE REMOVABLE IN ONE PIECE FOR ANNUAL MAINTENANCE
- 8) CURB COCK TO BE INSTALLED A DISTANCE OF 300mm-500mm FROM MAIN.



Engineering
Department

19mm MANHOLE BLEEDER DETAIL DOUBLE CHECK VALVE

OCTOBER 2021

STD DWG

A6.5