



DETAIL "B"

NOTES:

1. ALL DIMENSIONS ARE IN MILLIMETRES.
2. FOR REVERSE GUTTER ON MONO SEE B1.0, B1.1, B1.2.
3. SHOULD A MONOLITHIC POUR NOT BE POSSIBLE 300 mm, 10M REINFORCING BARS SHALL BE INSERTED INTO THE BACK OF THE CURB AND GUTTER AT 750 mm CENTRE TO CENTRE SPACING STARTING AT 375 mm FROM A CONSTRUCTION JOINT.
4. FOR AREAS OF TRANSITION BETWEEN ROLLED CURB AND BARRIER CURB THE 100mm DIFFERENCE IN WIDTH SHALL BE BLENDED GRADUALLY AS THE FIELD INSPECTOR SEES FIT.



**MONOLITHIC CURB, GUTTER & SIDEWALK
150mm BARRIER CURB**

DATE: JANUARY 2015

STD DWG

B3.1