



CITY OF WHITEHORSE
ENGINEERING SERVICES &
WATER & WASTE SERVICES

AMENDMENT NOTICE
REVISION TO ACCEPTED WATER METERS

Date: April 12, 2022

File: 2022_AN_SSM_006

General

This notice is intended to inform stakeholders of a change to water meters accepted by the City of Whitehorse.

The following section of the City of Whitehorse Servicing Standards Manual (SSM) is affected by these changes:

Section 4 – Standard Drawings A4.8, A4.9 and A4.10

Approved Alternate

Due to issues currently experienced with water meter installations, the City is revising the accepted water meters – as noted on City Standard Drawings A4.8, A4.9 and A4.10.

The current note on the standard drawings 'Water meter is to be Badger Brand and is to meet IP68 specifications' is revised to 'Water meter is to be Sensus Hydroverses, ABB Watermasters or equivalent and meet IP68 specifications'.

Should you require further information regarding the above changes please contact Engineering Services at (867) 668-8305.